

JVPL/EC/ES/2018-19

June 22<sup>nd</sup>, 2019

**The Member Secretary**  
**M.P. Pollution Control Board,**  
**Paryavaran Parisar,**  
**E-5, Arera Colony**  
**BHOPAL (M.P.) - 462 016.**

**Sub: Environment Statement under the Environment (Protection) Act, 1986 for Jaypee Nigrie Super Thermal Power Project (A Division of Jaiprakash Power Ventures Limited) at village Nigrie, Dist. Singrauli.**

Dear Sir

Please find enclosed herewith Environment Statements for the year 2018 - 2019 of our following Plants.

- Jaypee Nigrie Super Thermal Power Project, EC reference no. J-13012/223/2007-IA-II(T) dated 25.02.2010 and its amendment dated 13.07.2012 for the Jaypee Nigrie Super Thermal Power Plant (2x660 MW) & Jaypee Nigrie Cement Grinding Unit (2.0 MTPA)

Thanking you.

Yours Faithfully  
**For (Jaypee Nigrie Super Thermal Power Project)**  
(A Division of Jaiprakash Power Ventures Ltd.)



**(Vinod Sharma)**  
Sr. President (O & M)

Encl: As Above.

1) C.C.: Regional Officer  
M.P. Pollution Control Board,  
Bhakuar, Naugadh,  
Singrauli District (M.P.) - 486885.

- For information please.

# ENVIRONMENTAL STATEMENT REPORT

## JAYPEE NIGRIE SUPER THERMAL POWER PLANT

(A Division of M/s Jaiprakash Power Ventures Limited)

Village: Nigrie, Tehsil: Sarai  
District: Singrauli

2018 – 2019

**SUBMITTED**

to

**M.P. POLLUTION CONTROL BOARD  
BHOPAL (M.P.)**

*Jaypee Nigrie Super Thermal Power Plant*  
(A Division of Jaiprakash Power Ventures Limited)

**Factory/Plant in Operation:** Jaypee Nigrie Super Thermal Power plant at Nigrie.

**Introduction:**

Jaiprakash Associates Ltd. (JAL), the flagship company of the Jaypee Group. JAL was formed due to merger of Jaiprakash Industries (JIL) and Jaiprakash Cement (JCL). JAL is the Engineering and Construction arm of the Jaypee group focused on development of River Valley and Hydro Electric Projects and a leader in Construction of River Valley and Hydropower Projects on turnkey basis for more than four decades. The company is currently executing various projects in Hydropower / Irrigation / other Infrastructure fields.

Jaiprakash Power Ventures Limited (JPVL) earlier known as Jaiprakash Hydro Power (JHPL), is a part of the Jaypee Group. The Company is engaged in the business of Generation of Power (Hydro & Thermal), Cement Grinding and Captive Coal Mining and Transmission of Power. Besides the 400MW Jaypee Vishnuprayag Hydro Power Plant in Uttarakhand; (3×660 MW) 1980MW Prayagraj Power Generation Company Limited in Uttar Pradesh, 500MW Phase I (of 1200 MW) Jaypee Bina Thermal Power Plant in Madhya Pradesh & (2X660 MW) 1320MW Jaypee Nigrie Supercritical Thermal Power Plant in Madhya Pradesh and Amelia (North) Coal Mine in Madhya Pradesh is dedicated Coal Mine to Jaypee Nigrie Super Thermal Power plant. The Company has a Captive Cement Grinding Unit named 'Jaypee Nigrie Cement Grinding Unit' at Nigrie (M.P.) with a capacity of 2 MTPA, which is utilizing generated Fly Ash from Jaypee Nigrie Super Thermal Power Plant.

Jaypee Nigrie Super Thermal Power Plant is a Coal Based Super Critical Thermal Power Plant of (660 × 2) 1320 MW at Nigrie Village, Sarai Tehsil in Singrauli District of Madhya Pradesh State having adjacent Cement Grinding Unit. Jaypee Nigrie Super (Critical) Thermal Power Plant commenced its operations w.e.f. 3<sup>rd</sup> September, 2014 (Unit # 01) & 24<sup>th</sup> March, 2015 (Unit # 02).

Supply of Super-Critical Boilers was executed by L & T - Power Boilers while the Steam Turbine Generator was sourced from L & T - Power. Boilers installed are with Super-Critical Steam Parameters and with High Efficiency resulting in Less Fuel Consumption and Less Environmental Pollution.

**Features:**

- Greater operating flexibility.
- Improved thermal efficiency.
- Lower emission levels.
- Reduced ash generation.
- Reduced fuel consumption.
- Reduced PM, NO<sub>x</sub> emission.
- Reduction of carbon dioxide emission due to less consumption of fuel.
- Super critical boiler technology will achieve a higher net efficiency level for coal fired power stations. This technology's higher steam temperatures and pressure parameters offer the most economical way to improve plant efficiency and operating flexibility – as well as achieve fuel cost savings and lower emissions for each KWH of electricity.

**Environment**

Efforts are made to Conserve Ecological Balance without any harm done to the local flora & Fauna. JPVL has also taken Green Initiatives, afforestation, Resources Conservation, Water Conservation, and Air Quality Control & Noise Pollution Control.

**“FORM - V”**

(See rule 14)

**ENVIRONMENTAL STATEMENT FOR THE FINANCIAL YEAR ENDING THE  
31<sup>st</sup> March 2019**

**PART - A**

(I)	Name & Address of the Owner / Occupier of the Industry Operation or Process	<b>Jaypee Nigrie Super Thermal Power Plant (JNSTPP) (A Division of Jaiprakash Power Ventures Limited)</b> PO- Nigrie, Distt. Singrauli-486669 Madhya Pradesh
(II)	Industry category Primary - (STC Code) Secondary - (SIC Code)	17 Category / 'RED' Category And Large Scale (Namely Thermal Power Generation Plant), Major
(III)	Production Capacity Unit-I Unit-II	2x660 MW Power Generation
(IV)	Year of Establishment Unit-I Unit-II	Year 2014 Year 2015
(V)	Date of last Environmental Statement Submitted	September, 2018

**PART - B**

**Water & Raw Material Consumption**

**A. Water Consumption - m<sup>3</sup>/day**

(I) Process	-	508.59
Cooling	-	20934.86
Domestic	-	795.00

Name of the Product	Process Water Consumption per unit of Product Output (m <sup>3</sup> /MU) (1 Mu=1000000 KW)	
	During the Previous Financial Year (2017-2018)	During the Current Financial Year (2018-2019)
Electricity	43.13	43.85

**(ii). Raw Material Consumption**

Name of the Raw Material	Name of Product	Consumption of Raw Material per Unit Product Output (MT/MU of Electricity ) (1 Mu=1000000 KW)	
		During the Previous Financial Year (2017-2018)	During the Current Financial Year (2018-2019)
Coal	Electricity	• 577.01	• 555.34
Fuel Oil (HFO & LDO)		• 0.4293	• 0.2814
<b>Chemicals-</b>			
• Hydrochloric acid (HCL)		• 0.0951	• 0.1152
• H <sub>2</sub> SO <sub>4</sub>		• 0.0244	• 0.0287
• NaOH		• 0.0741	• 0.0792
• Ammonia		• 0.0072	• 0.0073
• Hydrazine	• 0.0000	• 0.0001	

<ul style="list-style-type: none"> <li>• Alum</li> <li>• NaOCl</li> <li>• Hydrogen Gas</li> <li>• CO<sub>2</sub> Gas</li> <li>• Chlorine Gas</li> <li>• Ferric Chloride</li> <li>• Dolomite</li> </ul>		<ul style="list-style-type: none"> <li>• 0.0143</li> <li>• 0.0020</li> <li>• 0.0001</li> <li>• 0.0002</li> <li>• 0.0215</li> <li>• 0.0007</li> <li>• 0.0052</li> </ul>	<ul style="list-style-type: none"> <li>• 0.0189</li> <li>• 0.0085</li> <li>• 0.0014</li> <li>• 0.0002</li> <li>• 0.0212</li> <li>• 0.0099</li> <li>• 0.0109</li> </ul>
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--	------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Total Electricity Generation MU (1 MU=1000000 KW)**

Name of Product	During Previous Financial Year (17-18) MU	During Current Financial Year (18-19) MU
Electricity	7688.93	7330.44

**PART - C**

**Pollutant Discharged To Environment / Unit of Output**

(Parameters as specified in the consent issued)

S. No.	Pollutants	Quantity of Pollutants Discharged (Mass / day) (tonne/day)	Concentrations of Pollutants in discharged (Mass / Volume) (mg/Nm <sup>3</sup> )	Percentage of variation from prescribed standard with reasons
(a)	<b>Water</b>			
(i)	<b>Domestic</b>	Zero discharge is being maintained and treated domestic waste water is being used in Horticulture & Green belt development.		
(ii)	<b>Industrial</b>	Zero discharge is being maintained. Treated waste water is reused in Cooling Water makeup & sprinkling in coal handling plant.		
(b)	<b>Air</b>			
	Monitoring of Ambient Air Quality parameters within limits and report attached as <b>Annexure- I</b>			
	<b>Stack emission</b>			
	<b>(a) ESPs</b>			
	Stack-I (Unit-I)	2.329	33.52	Within permissible limit

Parameter - PM			
Stack-II(Unit-II) Parameter - PM	2.333	33.57	

**PART - D**  
**Hazardous Wastes**

As specified under Hazardous and Other Waste (Management & Transboundary Movement) Rules, 2016

Hazardous Waste		Total Quantity (Kg)					
		During the Previous Financial Year (2017-2018)			During the Current Financial Year (2018-2019)		
(a)	From Process	Used oil	Waste oil	Resins	Used oil	Waste oil	Resins
				Nil	15,240 kg	Nil	Nil
(b)	From Pollution Control Facilities.	NA			NA		

**PART - E**  
**Solid Wastes**

Solid Waste		Total Quantity	
		During the Previous Financial Year (2017-2018)	During the Current Financial Year (2018-2019)
(a)	From Process	Bottom Ash (2,71,285 MT)	Bottom Ash (2,20,892 MT)
(b)	From Pollution Control facilities	Fly Ash (12,12,655 MT) All the collected material is utilized in manufacturing of PPC and used in Ash dyke Raising & Landfill within the premises.	Fly Ash (10,78,454 MT) All the collected material is utilized in manufacturing of PPC and Fly Ash Bricks.



(c)	(i) Qty. recycled or reutilised within the unit.	Fly Ash (32439 MT) (Utilized in adjacent Cement Grinding unit of Jaypee Nigrie )	Fly Ash (13965 MT) (Utilized in adjacent Cement Grinding unit of Jaypee Nigrie )
	(ii) Sold	11,80,216 MT of Fly Ash utilized by Cement Manufacturers & Brick Manufacturers & in Ash Dyke Raising/ Low lying Area Filling & Local Gram Panchayath (100% Fly Ash is being utilized.)	10,64,489 MT of Fly Ash utilized by Cement Manufacturers & Brick Manufacturers (100% Fly Ash is being utilized.)
	(iii) Disposed	Bottom Ash (2,71,285 MT) is disposed in Ash Pond (174300 MT of Bottom Ash has been utilized in Low lying area filling).	Bottom Ash (2,20,892 MT) is disposed in Ash Pond. 73,060 MT of Pond Ash used by Cement Manufacturers & Brick Manufacturers.

**PART - F**

**PLEASE SPECIFY THE CHARACTERISATIONS (IN TERMS OF COMPOSITION AND QUANTUM) OF HAZARDOUS AS WELL AS SOLID WASTES AND INDICATE DISPOSAL PRACTICE ADOPTED FOR BOTH THESE CATEGORIES OF WASTES.**

**Hazardous waste:** Generated Haz. Waste is being stored under covered shed at an isolated covered place; the floor is concreted & person working at site has been provided with all required PPEs. From there the stored hazardous waste will be sold out to authorized recyclers.

**Solid waste:** Fly Ash & Bottom Ash are being generated in form of solid waste from Jaypee Nigrie Super Thermal Power Plant for which suitable provisions are made for its use-

- Fly Ash is being consumed by its adjacent Jaypee Nigrie Cement Grinding Unit & rest is transported to nearby Cement Plants (Jaypee Rewa, PCL Satna, Birla Corp Satna, KJS Maihar, VTC Maihar & Other Brick manufacturing Unit) for manufacturing of PPC and manufacturing of fly ash bricks.
- **Ash Water Recirculation System & Clarifier System:-**

The Bottom ash slurry is being disposed through ash slurry pumps to ash dyke. In the ash dyke ash particles settled and the ash water is recovered from the dyke for re-circulation/re-use. The ash water flows from ash dyke to ash water recovery system. In the recovery system the ash water from the ash dyke received at stilling chamber and pumped to flash mixer where required coagulants are being added. The water from the flash mixer flows to the clariflocculator where contaminated ash sludge being separated and the clear water from the clarifier pumped back to ash water sump for re-use.
- Ash Ponds are lined with fine sand then HDPE (1 mm thickness) lining and over that PCC. Bottom Ash will also be suitably utilized after drying to meet the stipulation of Fly ash Notifications.



Ash Dyke Pond

## PART - G

### IMPACT OF THE POLLUTION ABATEMENT MEASURES TAKEN ON CONSERVATION OF NATURAL RESOURCES AND ON THE COST OF PRODUCTION.

Following measures have been adopted for abatement of pollution, conservation of natural resources:-

#### **a) Utilization of Fly Ash for the manufacturing of cement**

JNSTPP having capacity of 2 x 660 MW has the potential to generate 1.477 MTPA (Fly ash = 1.177 MTPA & Bottom Ash 0.30 MTPA). Generated Fly ash is consumed in adjacent Jaypee Nigrie Cement Grinding Unit & rest is transported to nearby Cement Plants (Jaypee Rewa, PCL Satna, Birla Corp Satna, KJS Maihar, VTC Maihar & Other Brick manufacturing Unit) for manufacturing of PPC and manufacturing of fly ash bricks.

#### **b) Installation of Sewage Treatment Plant & Effluent Treatment Plant (ETP)-**

Adequate facilities for treatment of industrial waste water including blow down from Cooling Towers. The waste water is treated in the ETP and the quality of treated water conforms to MPPCB standards as given in Consent Order and reused in makeup of condenser cooling water & dust suppression in CHP. Sewage Treatment Plant of 1000 KLD in Township & 100 KLD in Plant area have been installed and treated water is used for horticulture.



## Waste water Treatment Plant (ETP)



Photograph of WWTP

### c). Installation of APCDs at various sources-

Highly efficient Electrostatic Precipitators (ESPs) with efficiency of 99.93% have been installed for each boiler to meet particulate emission less than 50 mg/Nm<sup>3</sup> with one field out of service at full load with worst coal. The ESP's engineering, supply and erection & commissioning work is done by M/s. BHEL (A Govt. of India Undertaking). Each ESP has six passes and each pass is having 16 fields (i.e. total 96 fields). We have installed 10 no. of bag filters at various point sources to control the fugitive emission.



Photograph of ESP

**d) Online Monitoring system:**

- ✓ Four Continuous Ambient Air Quality Monitoring Stations (Online/Real Time) are provided along the boundary considering the wind rose/wind directions of PM 10, PM 2.5, SO<sub>2</sub>, NO<sub>x</sub> & CO and the total data of the CAAQMS is connected with MPPCB server at Bhopal & CPCB server at Delhi.
- ✓ Online Continuous Emission Monitoring Analyzers installed to Monitor Emissions (PM, SO<sub>2</sub> & NO<sub>x</sub> & Hg) for both boiler stacks and data is being transmitted to MPPCB & CPCB servers, and the results are well within the Norms.

CAAQMS



Opacity Meter & CEMS



Photo of CAAQMs & CEMS

**e). Installation of Water Sprinkling Systems-** Water spraying arrangements are made for control of fugitive emission from Coal handling plant and other areas by installation of Water Sprinklers.



Photograph of sprinkler at coal stacker

**f).Noise Pollution Abatement Measures** – Provision of Acoustic Enclosures at Turbines & other Machineries to attenuate Noise Levels. Acoustic Enclosures of Machines to control Noise Levels.



**g). Good housekeeping practice adopted**

Following measures have been taken for good house keeping

- a. The conveyer belts are fully covered.
- b. Schedule maintenance of Pollution Control Devices is carried out.
- c. Coal Wagon bottom unloading System is installed.



**CHP and covered conveyer belts**



**Coal wagon unloading system**

## PART - H

### ADDITIONAL MEASURES / INVESTMENT PROPOSALS FOR ENVIRONMENTAL PROTECTION INCLUDING ABATEMENT POLLUTION, PREVENTION OF POLLUTION.

**Additional measures taken for Environmental Protection are as under**

#### **Extensive plantation in and around the Plant.**

We have a dedicated team of skilled horticulturists for the Afforestation and greenery development program at our plant under the supervision of senior experienced person. Till date we have planted approximately 2.82 lakhs (2,81,805 nos.) of plants in around 114 Ha. (113.66 ha.)

#### **Steps taken to protect plantation:**

1. Barricading provided for protection of plants.
2. Two numbers of dedicated water tankers are provided for regular watering of plant.
3. Dedicated manpower is provided for regular watering & care of plants.
4. Tree Guards are provided for protection of the plants.





## PART - I

### ANY OTHER PARTICULARS FOR IMPROVING THE QUALITY OF ENVIRONMENT.

- Water Harvesting Measures- A surface water body is constructed in the township area for rain water harvesting.



- Establishment of Environment Laboratory-

Environment Laboratory has been set up with well equipped facilities such as water & waste water testing instruments as well Air Quality Monitoring instruments.



**Environment Cell**

- Concreting of Roads- All internal roads in plant & township area are made Pucca.



- **CSR works -**

- A separate budget earmarked for CSR activities. CSR study report already submitted to the ministry vide letter no. - JPVL/JNSTPP/MOEF/2010 dated 20.01.2011 and 29.06.2011.
- The company is carrying out CSR activities in the vicinity of the Project as per the directions and guidance of the District Administration.
- Providing drinking water facility benefitting to the nearby villages (Nigrie, Niwas, katai & Hardi & Mahua Ganv and Chamrach and Joba).
- Unit is also investing on CSR Activities like conducting Medical camps in villages (Nigrie, Niwas, katai & Hardi & Mahua Ganv and Chamrach), Plantation programs (Nigrie, Niwas, katai & Hardi & Mahua Ganv and Joba), Road development activities (Nigrie), women empowerment and maintenance of Bore wells in nearby villages (Nigrie) & providing furniture/building material to local offices (Primary & Middle School in Nigrie and Higher Secondary School in Niwas, Promotion of Safety/Cultural/sports in Rural Areas/villages (Nigrie, Niwas)
- Total expenditure incurred up to March, 2019 is Rs 3.13 Crores.

Based on Need Base Assessment Study for development of nearby villages, an action plan was worked out for income generating projects for up-liftment of poor section of society.

**The following activities were undertaken:**

- Sardar Patel Uchchar Madhyamik Vidyalaya was started functioning up to class five w.e.f. July, 2011 and subsequently upgraded up to 10th class in July'2016 session.
- Free Education & Free Mid Day Meals provided to the children of affected village Nigrie & Sardar patel School, Nigrie.
- Free Health Check Up & Health cards provided to the 328 students.
- Roads have been laid down in Nigrie Village & free electricity supply to the Street Lights is providing in R & R Colony.
- Restoration & Refurbishment of water reservoirs & ponds taken place in nearby villages (Karondia Nallah in Papal Gaon & Saraiha Talab in Nigrie Ghat Nirman).
- Providing Mobile Hospital & Ambulance Service to affected villages (Nigrie, Niwas, katai & Hardi & Mahua Ganv and Chamrach and Joba).
- An Average of 3645 patients are being benefited every month by the Primary Health Center.

- A Dispensary was also setup in R & R colony. An Average of 300 patients are being benefited every month.
- **“Trasform Singrauli” Project under Indian government and MP Government:-**
  1. Provided Free Medical Checkup facility & Free Medicines in Nigrie, Niwas, katai & Hardi & Mahua Ganv and Chamrach Villages.
  2. Continual supply of Protein Powder, Iron Syrups & Jaggery and Horse Gram to about 250 Pregnant Women in above mentioned 6 villages.
  3. Multi Vitamin Drops & Zinc Drops have been provided to Malnourished Babies in the villages.
- **Swatch Bharath Mission:-**
  1. Provided Dust Bins in 31 Angan Wadi Centres.
  2. Awareness programmes conducted through posters Swachata Abiyan in Angan Wadi Cenetrs & rural areas.
  3. 180 Fruit Yielding plants have been planted through Gram Pnachayath in 6 villages.
- **Hindi Medium School- Free Education for nearby villagers-**



- Free Medical Camps –



- Free Medicines to all nearby Villagers - A 10 bed hospital is functional for medical check-up and treatment to the local habitats for the surrounding 10 villages. Almost 250 to 300 people avail the Medical facilities daily



For Jaypee Nigrie Super Thermal Power Plant,  
(A Division of Jaiprakash Power Ventures Ltd)

Handwritten signature of Vinod Sharma

(Vinod Sharma)

Sr. President (O & M)

Vinod Sharma  
Sr. President (O & M)  
Jaypee Nigrie Super Thermal Power Plant, Nigrie  
(A Unit of Jaiprakash PowerVenture Ltd.)  
Singrauli-486659 (M.P.)

**JAYPEE NIGRIE SUPER THERMAL POWER PLANT**  
(A Division of Jaiprakash Power Ventures Limited)

AMBIENT AIR QUALITY MONITORING REPORT

Period : April 2018 - March 2019

Near STP - Colony area						
Month	Particulars	PM <sub>2.5</sub> (µg/m <sup>3</sup> )	PM <sub>10</sub> (µg/m <sup>3</sup> )	SO <sub>2</sub> (µg/m <sup>3</sup> )	NO <sub>x</sub> (µg/m <sup>3</sup> )	CO (mg/m <sup>3</sup> )
Apr-18	Monthly Average	26.0	62.8	6.6	11.2	0.54
May-18		24.0	59.2	6.1	9.7	0.52
Jun-18		23.1	56.5	5.4	8.9	0.53
Jul-18		20.8	52.7	5.3	7.8	0.54
Aug-18		18.8	50.2	5.2	7.0	0.53
Sep-18		17.4	46.1	5.1	6.5	0.52
Oct-18		22.6	52.8	6.4	7.1	0.62
Nov-18		24.7	55.0	7.0	8.0	0.64
Dec-18		31.1	60.6	7.2	10.1	0.66
Jan-19		29.3	58.6	6.9	9.3	0.62
Feb-19		27.7	54.9	6.5	8.3	0.57
Mar-19		25.7	53.5	6.1	8.0	0.55
Near H <sub>2</sub> Gas cylinder shed						
Month	Particulars	PM <sub>2.5</sub> (µg/m <sup>3</sup> )	PM <sub>10</sub> (µg/m <sup>3</sup> )	SO <sub>2</sub> (µg/m <sup>3</sup> )	NO <sub>x</sub> (µg/m <sup>3</sup> )	CO (mg/m <sup>3</sup> )
Apr-18	Monthly Average	29.1	58.7	5.9	11.4	0.53
May-18		26.6	46.3	5.4	10.8	0.53
Jun-18		25.3	58.2	5.3	9.8	0.54
Jul-18		23.5	56.3	5.2	8.4	0.51
Aug-18		21.1	51.2	5.2	8.0	0.52
Sep-18		20.0	48.2	5.1	7.4	0.51
Oct-18		23.5	51.2	6.4	8.2	0.54
Nov-18		25.1	55.3	6.9	8.9	0.60
Dec-18		32.0	63.7	7.8	12.8	0.58
Jan-19		30.6	61.5	7.3	10.7	0.56
Feb-19		28.4	58.0	7.0	8.8	0.55
Mar-19		27.3	57.5	6.9	8.5	0.53
Near Watch tower 22 (Grinding Unit)						
Month	Particulars	PM <sub>2.5</sub> (µg/m <sup>3</sup> )	PM <sub>10</sub> (µg/m <sup>3</sup> )	SO <sub>2</sub> (µg/m <sup>3</sup> )	NO <sub>x</sub> (µg/m <sup>3</sup> )	CO (mg/m <sup>3</sup> )
Apr-18	Monthly Average	37.8	68.5	6.9	15.6	0.52
May-18		33.1	65.6	6.6	14.6	0.51
Jun-18		31.6	63.6	5.8	12.2	0.54
Jul-18		29.4	60.1	5.6	10.1	0.53
Aug-18		25.9	58.1	5.4	9.6	0.53
Sep-18		23.7	56.2	5.6	9.0	0.56
Oct-18		30.1	63.9	7.1	10.4	0.63
Nov-18		32.4	65.6	8.0	77.4	0.66
Dec-18		40.1	71.0	10.1	15.3	0.68
Jan-19		38.1	69.0	9.0	13.0	0.64
Feb-19		34.9	65.8	8.7	11.1	0.61
Mar-19		33.8	64.6	8.3	10.0	0.59
Near fuel storage tank						
Month	Particulars	PM <sub>2.5</sub> (µg/m <sup>3</sup> )	PM <sub>10</sub> (µg/m <sup>3</sup> )	SO <sub>2</sub> (µg/m <sup>3</sup> )	NO <sub>x</sub> (µg/m <sup>3</sup> )	CO (mg/m <sup>3</sup> )
Apr-18	Monthly Average	29.5	61.6	6.6	13.8	0.55
May-18		26.2	57.1	5.5	11.4	0.54
Jun-18		26.3	59.6	5.7	10.2	0.52
Jul-18		24.0	54.3	5.5	8.9	0.54
Aug-18		23.3	52.9	5.3	8.4	0.52
Sep-18		21.6	50.1	5.2	7.8	0.52
Oct-18		25.0	58.2	6.8	9.2	0.62
Nov-18		27.3	61.1	7.2	10.1	0.65
Dec-18		38.3	68.3	9.7	13.1	0.69
Jan-19		36.0	65.3	8.2	10.1	0.65
Feb-19		32.3	60.8	7.4	9.0	0.60
Mar-19		30.1	59.8	7.1	8.5	0.55